

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE

NEW DELHI-110 001.

No.F.6/DFS/MS/School/2021/SZ/182

Dated: 03/03/2021

**FIRE SAFETY CERTIFICATE**

Certified that the Kalinga Institute of Social Science Delhi Government Sr. Secondary Residential School, Issapur, New Delhi-110073, comprised of ground plus two upper floors, owned/occupied by Kalinga Institute of Social Science was issued Fire Safety Certificate by this department vide letter no. F6/DFS/MS/School/2017/SZ/299 dated 24/08/2020. The School building was re-inspected by the officer concerned of this department on 22/02/2021 in the presence of Sh. Udaibir Sharma (Admin.) and found that the School building have deemed complied the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class "Educational" for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....03/03/2021..... at New Delhi.

(Sunil Chawdhary)  
Dy. Chief Fire Officer

ok/ls

Copy to:-

1. The Manager,  
Kalinga Institute of Social Science Delhi Government Sr.  
Secondary Residential School, Issapur, New Delhi-110073
2. Director of Education,  
Govt. of NCT of Delhi, Old Secretariat,  
New Delhi-110054.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape shall be kept unlocked and unobstructed for unhindered evacuation of occupants in case of emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

Principal

Kalinga Institute of Social Sciences  
Delhi Gov. Sr. Sec. Residential School  
Village Issapur, Najafgarh  
Delhi-110073

Scanned by CamScanner

Scanned with OKEN Scanner

Scanned with OKEN Scanner